



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-7

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/615

Dated: 04/07/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s The Queens Head Hotel, 2282,2283,2284 & 2285, Plot Khasra No. 486, Block-A, Chuna Mandi, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026051907124 dated 03/06/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 22/06/2026 in the presence of Sh. Gaurav, Owner and following shortcomings were observed: -

1. Electrical panels are not permitted in staircases.
2. Lift is not protected with lift lobby in basement.
3. Smoke Management System is not provided in basement.
4. Hose reel and Internal Hydrant is provided in basement.

Keeping in view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

01CBP

Copy to: -

1. The Manager, M/s The Queens Head Hotel, 2282,2283,2284 & 2285, Plot Khasra No. 486, Block-A, Chuna Mandi, Paharganj, New Delhi - 110055.