

C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F6/DFS/MS/School/2025/NDZ/587

Dated: 11 / 07 / 2025

To

The HOS,
Govt. Co-Ed(RDJK) Sr. Sec. School,
Bhajanpura, Delhi-110053.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o Govt. Co-Ed(RDJK) Sr. Sec. School, Bhajanpura, Delhi-110053.

Sir,

Please refer to your letter no. RDJK/CO-ED/BP/2025/247 dated 28/06/2025 on the subject cited above. In this connection it is to inform you that the school premises was visited by the officer concerned of this department on 05/07/2025 and observed that the shortcoming issued by this department vide letter No. F6/DFS/MS/School/2021/NDZ/173 dated 01/04/2021. (Copy Enclosed) still not complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Enclosed: As above

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2021/NDZ/ 173

Dated: 01/04/2021

To,
Assistant Engineer(E)
Edu.Elect.Sub-div.M1-3,
PWD, Hauz Khas
New Delhi-110016

Sub:- Regarding issuance of Fire Safety Certificate in r/o R. D. J .K .Govt. Co-Ed Sr. Sec. School ,Bhajanpura, Delhi.

Sir,
Please refer to your email dated 12/03/2021 on the subject cited above. In this regard, it is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mrs. Vijay Singh Rana (Site Incharge) of the school on dated 23/03/2021. During the course of inspection, the following shortcomings:-

1. The school building is not accessible for fire/emergency vehicles.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage.

Yours faithfully


31/3/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

Copy to:-

1. The Director of Education,
B-Block, Yamuna Vihar,
North - East, Delhi-110053.

