



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

C27



No. F.6/DFS/MS/School/2026/EZ/ 105

Dated: 28/07/2026

FIRE SAFETY CERTIFICATE

Certified that the **R.N. Memorial Public School** located at B-43, Shanti Nagar, Shiv Vihar, Delhi-110094, building comprised of ground plus one upper floor only, owned/occupied by R.N. Memorial Public School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2018/NDZ/2193 dated 26/09/2018. The premise was re-inspected by the officer concerned of this department on 30/06/2026 in the presence of Sh. Sachin Sharma (Teacher) and found that the said building/premises have complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 – 362 dated 17/01/2005 and that the building is fit for occupancy class “Educational” (Group B) with effect from 28/07/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/07/2026 at New Delhi by

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. The Principal, R.N. Memorial Public School located at B-43, Shanti Nagar, Shiv Vihar, Delhi-110094

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

4/14

INSPECTION REPORT				
1.	Name & address of the building	R.N. Memorial Public School at B-43, Shanti Nagar, Shiv Vihar, Delhi-110094		
2.	Type of Occupancy	Educational, Group 'B-1'		
3.	Building Comprised of	Ground plus one upper floor.		
4.	Type of Case	Renewal		
5.	Details of previous FSC No.	F.6/DFS/MS/School/2018/NDZ/2193 Dt. 26/09/2018		
6.	Fire safety directives letter No.	DOE Circular No. 262 – 362 dated 17.01.2005		
7.	Date of inspection	30/06/2026		
8.	Name of the Inspecting Officer	ADO (Gokalpur)		
9.	Name and designation of Officer from the building side	Sh. Sachin Sharma (Teacher)		
10.	Year of Construction	2005		
11.	Applicant's letter No./Online Appn.	No. 52026013000708		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old FSC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 No.	02 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.20m & 0.80m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 No.	Provided	MR
	e. Width of Corridor	1.50 mtr	1.60 mtr	MR
	f. Door Size	1.0 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos	06 Nos	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

87

2/15

7.	Automatic fire detection and alarming system.			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper floors.	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants.	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	220 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2,500 ltrs	Provided	MR
15.	Exit signage	N/A	N/A	N/A
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

82


N/16

19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A


The fire protection systems provided in the building/premises were checked, tested at random and **found functional at the time of inspection**. Further, the shortcomings observed and communicated against online application ID: **5206013000708** dated 26.02.2026 have been complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under DOE Circular dated 01.03.2011, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2018/NDZ/2193 dated 26/09/2018, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**

Accordingly, **DFA is put up for approval** and signature please.


 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (Gokalpur)

DO (ED)



 02/07/26

CFO (East Zone)


 4/7/26

Principal Director

CFO to be as per report of DO.


 13/7/26


CFO (East)



 24/7/26

ADO/GP

Str. F.T letter is put up for your sig. pl

CFO (East)


 27/7/26


 27.07.26

ms