



75
Azadi Ka
Amrit Mahotsav

C-87

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 287
To

Dated: 10 / 06 / 2025

The Joint Commissioner of Police,
Licensing Unit, First Floor,
Police Station Defence Colony,
New Delhi-110049

Sub: Inspection report from fire & life safety point of view in r/o M/s Rachna Tourist Lodge located at 8510, Arakashan Road, Pahar Ganj, New Delhi-110055

Sir,

Please refer to online portal (etl.mcdonline.nic.in) application No. 2025051008260 dated 26/04/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 27/05/2025 in the presence of Sh. Pankaj Gulati (Owner). During course of inspection, the shortcomings observed are as below.

1. Manual call points provided found non-functional.
2. Overhead water tank exclusive for firefighting found used for domestic purpose.
3. Loose hanging wires found in common corridor.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

[Signature]
9/6/2025

(Virendra Singh)
Chief Fire Officer
Ph. 011-2341433

[Signature]

Copy to: -

1. Authorized Signatory, M/s Rachna Tourist Lodge located at 8510, Arakashan Road, Pahar Ganj, New Delhi-110055