



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का
अमृत महोत्सव

C 33


Dated: 11/11/2025

No. F6/DFS/MS/School/SZ/2025/1302

FIRE SAFETY CERTIFICATE

Certified that the **Radha Krishan Vidya Niketan, Sector-4, Pushp Vihar, New Delhi-110017**, building comprised of Ground floor only, owned / occupied by Radha Krishan Vidya Niketan Delhi, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2022/SZ/1180 dated 21/10/2022. Now, the said premises was re-inspected by ADO/BCP of this department on 29/10/2025 in presence of Mrs. Monika Bhatnagar (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class **"Educational Building" (Group - B)** with effect from 11/11/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 11/11/2025 at New Delhi by.


(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
o/c @

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal Radha Krishan Vidya Niketan, Sector-4, Pushp Vihar, New Delhi-110017,

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

12/15
INSPECTION REPORT

01.	Name & address of the building	Radha Krishan Vidya Niketan, Sector-4, Pushp Vihar, New Delhi-110017		
02.	Building is comprised of	Ground floor only		
03.	Type of occupancy	Educational Building (Group-B)		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2022/SZ/1180 dated 21/10/2022		
06.	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
07.	Date of inspection	29.10.2025.		
08.	Name of the inspecting officers	Yashwant Singh Meena, ADO (BCP)		
09.	Name of the designation of officer from the building side	Mrs. Monika Bhatnagar (Principal)		
10.	Year of construction	2006		
11.	Applicant's letter no.	Outdoor dairy no. 6228 dated 19/09/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
	A Road width	Required	Approachable	MR
	B Gate width	Required	2 gate 4m.each	MR
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	N/A	N/A	N/A
	C Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	N/A	N/A	N/A
	C Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.0 mtr.	Provided	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	30 ACPH	N/A	N/A
	B Upper floor	12 ACPH	N/A	N/A
05.	Fire Extinguisher:			
	A Total numbers	12 nos.	12nos.	MR
	B Types	ABC/CO2	ABC&CO2	MR
	C ISI marking	ISI marked	Provided	MR


06. First-Aid-Hose Reel:				
	A	Total numbers of each floor	N/A	N/A
	B	Length of hose reel hose	N/A	N/A
	C	Nozzle diameter	N/A	N/A
07. Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A
	B	Location of main panel	N/A	N/A
	C	Location of repeater panel	N/A	N/A
	D	Alternate source of power	N/A	N/A
	E	Hooters	N/A	N/A
08. MOEFA:			N/A	N/A
09. Public Address System:			N/A	N/A
10. Automatic Sprinkler System:				
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A
11. Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A
	C	Hose box	N/A	N/A
12. Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A
	B	Hose box	N/A	N/A
13. Pumping Arrangements:				
1	Ground level			
	A	Discharge of main pump	N/A	N/A
	B	Head of main pump	N/A	N/A
	C	Number of main pumps	N/A	N/A
	D	Jockey pump out put	N/A	N/A
	E	Jockey pump head	N/A	N/A
	F	Standby pump out put	N/A	N/A
	G	Standby pump head	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A
	I	Pump house access	N/A	N/A
2	Terrace Level			
	A	Discharge of pump	N/A	N/A
	B	Head of the pump	N/A	N/A
	C	Power supply	N/A	N/A
	D	Auto starting of pump	N/A	N/A
14. Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	N/A	N/A
15. Exit Signage:			Required	Provided
				MR

n/17

16.	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17.	Standby Power Supply:		NA	N/A
18.	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19.	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20.	Special Fire Protection systems for protection of special Risks, if any:		NA	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.


Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter no F6/DFS/MS/School/2022/SZ/1180 dated 21/10/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is **recommended**.


 30/10/2025
 Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO/BCP


DO/SD

 30/10/25

~~Dy. Secy~~


 4/11/25
A.K. MALIK

Principal Director

Dy. Cfo to Secy.

 04/11/25


 Dy. Cfo (SZ)
A.K. MALIK

n. (K.O.)