



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 667

Dated: 21/08/2025

To

The Manager,
Radiant Brain Global School at
Gali No.09, Block-B Pradeep Vihar,
Nathupura, Delhi-110084

Sub: Regarding issuance of fire safety certificate in r/o Radiant Brain Global School at Khasra No-246, Gali No.09, Block-B Pradeep Vihar, Nathupura, Delhi-110084.

Sir,

Please refer to your letter no. Nil dated 14/07/2025 received in this department vide outdoor dairy no. 3868 dated 17/07/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 29/07/2025 to verify the fire safety measures issued vide NBC Part-IV/UBBL-2016 and observed that as per earlier Fire Safety Certificate issued by this department letter of even no. F6/DFS/MS/School/2022/752 dated 13/07/2022 the building was comprised of ground floor only. The school management has added one more floor now the building is comprised of Ground & first floor. At the time of inspection Smt. Ruchi (Manager) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 There is 02 nos. of staircases is provided from ground to first floor only against the requirement both staircases continues from ground to terrace level.
- 2 Terrace level fire water tank capacity of 3000Ltr against the requirement of 10,000 ltrs.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully


Virendra Singh
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi – 110054.