




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/19



No. F6/DFS/MS/WZ/2025/School/ 392
To,

Dated: 14/05/2025

The Principal,
Rahul Public School,
D-16, Rajiv Nagar Ext. Rohini,
Delhi-110086.

Sub: Issue of FSC in r/o Rahul Public School, D-16, Rajiv Nagar Ext. Rohini, Delhi-110086.

Sir,

Kindly refer to letter received in this department through outdoor diary no. 14932 dated 24.03.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **21.04.2025**, in presence of **Mr. Rahul Solanki** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. First Aid hose reel not provided on ground + 01 block.
2. The required exit signage are not provided.
3. Travel distance is not meeting the requirement of dead end on Gr. + 01 block & Gr. + 02 block.
4. An overhead water storage tank capacity of 10,000 ltrs & pump of 450lpm is not provided in ground + 01 upper floor.
5. The width of alternate staircase is 1.5m not provided Gr. + 01 block & Gr. + 02 block.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000
24