

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2025/SZ/226

Dated: 09/05/2025

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Rahul Guest House at
5577, Gali Shora Kothi Basant Road Pahar Ganj, New Delhi
Sir,

This has reference with **MCD Portal 2025041206250 dated 12/04/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 08/05/2025 in the presence of Mr. Hasib Alam and observed that building comprised of Ground + 02 upper floors and following shortcomings were observed during inspection :

1. Smoke Exhaust fan found removed.
2. Carbon monoxide detector not provided as per clause 7.31 of UBBL 2016.
3. Fire fighting pumps capacity 180 LPM provided but not working properly.
4. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

9/5/25
8/5