



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ 423
To,

Dated: 27/08/2025

Dr. Ashutosh Gupta (Head of Office),
SRHC Hospital, Narela,
Delhi- 110040.

Sub: - Renewal of FSC in r/o M/s. Satyawadi Raja Harishchandra Hospital, Plot No. 30, Sec. 7 A, Narela, Delhi- 110040.



Sir,

This is in reference to your letter no. F.3(212)/SRHC/H&FW/CT/Fire Service/2011/5617 dated 12/06/2025 received through outdoor diary no. 2802 dated 17/06/2025 on the subject cited above. In this connection, it is to inform you that the above said hospital building was re-inspected by the officer concerned by this department on 28/07/2025 in the presence of Sh. S.N. Sharma (Supervisor, Electrical) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/WZ/2025/31 dated 20/01/2025. During the course of inspection it was observed that fire fighting systems like pumping system, first aid hose reels, internal hydrants, MOEFA, P.A. system etc. found functional but **one shortcoming is still not rectified**. The status of shortcoming is as under:-

Sr. No	Shortcomings	Status
1.	Internal Road of 6 m found obstructed by new construction.	Not Rectified
2.	Fire check door in basement found broken.	Rectified
3.	Fire control room and patient registration room shall be separate.	Rectified

In view of the above shortcomings, the application for **renewal of Fire Safety Certificate is not considered at this stage & rejected**. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer


Copy to:-

1. The Executive Engineer, PWD (Electrical), HMED, North Dr. BSA Hospital, Sec. 6, Rohini, Delhi-110085.