

c-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 602

Dated: 05/05/2025

FIRE SAFETY CERTIFICATE

Certified that the Rajan D S Public School, located at Ground & 1st floor, A-762, Shastri Nagar, Delhi – 110052, in a building comprised of Ground Floor + 03 Upper Floors, owned/Occupied by Rajan D S Public School, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/84 dated 01/02/2022. The premises was re - inspected by the officer concerned by this department on 23/04/2025, in the presence of Sh. Rajan Dhiman (Manager) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The building/premises have deemed complied with fire prevention and fire safety requirements in accordance with DOE, Circular No.3298-3398 dated 01/03/2011 and found that the building / premises is fit for the occupancy class "Educational" Group B (Ground & 1st Floor only) with effect from 05/05/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 05/05/2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat.
2. The Principal, M/s. Rajan D S Public School, located at Ground & 1st floor, A-762, Shastri Nagar, Delhi – 110052. **Email ID:-rajandsps@gmail.com.**

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. Owner/occupier has given an undertaking (places on C-36) that second & third is using for residential purpose. If it will be used for school activity/purpose FSC shall be null & void automatically.

2.	Type of Occupancy	Rajan D S Public School, located at Ground & 1 st floor, A-762, Shastri Nagar, Delhi - 110052.
3.	Type of Case	Educational(Ground + 01 Upper Floor in School and Residence on 02 nd Floor & 3 rd Upper Floor)
4.	Details of previous NOC	Renewal
5.	Fire Safety directives letter No	F6/DFS/MS/School/WZ/2022/84 dated 01/02/2022.
6.	Date of inspection	DOE 3298-3398 dated 01/03/2011
7.	Name of the Inspecting Officers	23/04/2025
8.	Name and designation of officers from the building side	Sarabjeet Singh ADO (MN) Sh. Rajan Dhiman (Manager)
9.	Year of Construction	1988-89 (As per previous Inspection Report dated 19/01/2022)
10.	Applicant's letter No.	Outdoor Dairy no.14650 dated 18/03/2025

The said school is running at Ground + 1st Floor, in a building comprised of Ground + 03 Upper Floor, was issued FSC vide letter no. F6/DFS/MS/School/WZ/2022/84 dated 01/02/2022 (Ground & 1st Floor only).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1x150 cm	2x94 cm	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	One	NA
	e. Width of Corridor	NA	144 cm	NA
	f. Door Size	1.0 m	1m Provided include door frame	MR(old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	06 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

Standby power supply		NA	NA	NA
Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Note :- Owner/occupier has given an undertaking (places at C-36) that second & third is using for residential purpose. If it will be used for school activity/purpose FSC shall be null & void automatically.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/84 dated 01/02/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

8/ADD/MN
25/04/2025

25/04/2025

25/4/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

28/4

28/4/2025

29/4/25

CFOI-578-UP
Dated-28/4/2025

Sir, F.T is put up for your kind personal signature

28/5/25

02/5/2025