




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 526

Dated: 17/06/2025

To

The Manager,
Rajdhani Public School
Shora Kothi, Ghanta Ghar, Delhi-07.

Sub: Regarding issuance of fire safety certificate in r/o Rajdhani Public School located at Shora Kothi, Ghanta Ghar, Delhi-110007.

Sir,

Please refer to your letter no. Nil dated 15/05/2025 received in this department vide outdoor dairy no. 1687 dated 15/05/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02/06/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Sh. C.P. Sharma (Manager) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 The school premises is not accessible to fire engine in case of emergency.
- 2 All classrooms door size is 76 to 80 cm against the requirement of 01m.
- 3 Hose reel hose is not provided.
- 4 Terrace level fire fighting pump capacity of 450 lpm is not provided.
- 5 Terrace level fire water tank capacity of 10,000 ltrs is not provided.
- 6 Exit signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

g/e

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.