



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-49  
75  
आजादी का  
अमृत महोसूल

No. F6/DFS/MS/School/2026/ 73

Dated: 23/01/2026

To,

Ms. Nikita,  
Vice Principal/HoS.  
Rajkiya Pratibha Vikas Vidyalaya,  
Link Road, Plot No.1, Jhandewalan,  
New Delhi - 110005.

**Sub: Regarding renewal of FSC in r/o Rajkiya Partibha Vikas Vidyalaya located at Plot No. 01, Link Road, Jhandewalan, New Delhi.**

Sir,

Please refer to letter No. RPVV/LKRB/2025/156 dated 17.09.25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 16/10/2025 in the presence of Mohd. Iftekhar Alam, Teacher and following shortcomings were observed: -

1. Hose reel pipes found damaged and nozzles found missing.
2. Fire pump provided on terrace found non-functional.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy To: -

1. Director of Education, Government of NCT of Delhi, Old Secretariat, Civil Lines, Delhi -110054.