




No. F6/DFS/MS/School/NDZ/2025/ 927

Dated: 28/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Rajkiya Pratibha Vikas Vidyalaya** located at **B-Block Yamuna Vihar, Delhi-110053**, comprised of Ground plus three upper floors, owned / occupied by **Rajkiya Pratibha Vikas Vidyalaya** was issued FSC vide letter No. F6/DFS/MS/School/2014/NDZ/213 dated 11/02/2014. The School building have complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and re-inspected by the officer concerned of this department on 11/07/2025 in presence of Mr. Harsh Kumar (Principal) of the school and that the school building is fit for occupancy class **"Educational Building" (Group - B)** with effect from 28/07/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010 & also conditions printed bellow.

Issued on 28/07/2025 at New Delhi by.


25/07/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
ok (w)

Copy to: -

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Principal, Rajkiya Pratibha Vikas Vidyalaya located at B-Block Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

01.	Name & address of the building	Rajkiya Pratibha Vikas Vidyalaya located at B-Block Yamuna Vihar, Delhi-110053.		
02.	Building is comprised of	Ground plus three upper floor only		
03.	Type of occupancy	Educational		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2014/NDZ/213 dated 11/02/2014		
06.	Fire safety directives letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011		
07.	Date of inspection	11/07/2025		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mr. Harsh Kumar (Principal)		
10.	Year of construction	1986		
11.	Applicant's letter no.	Outdoor dairy no.3366 dated 03/07/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NM R
01.	Access to Building:			
	A Road width	6.0 mtrs.	08 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Number of staircase	02 no.	03 no.	MR
	b Upper floor	02 no.	03 no. (1 stair upto 1 st floor)	MR
	c Basement	N/A	N/A	N/A
	B Width of staircases			
	a Width of staircase	1.50 mtrs.	1.5 m, 1.5 m, 4 m	MR
	b Upper floor	1.50 mtrs.	1.5 m, 1.5 m	MR
	c Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	1.50 mtrs.	1.50 mtrs	MR
	F Door size	1.0 mtr	1.0 mtr.	MR
03.	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

05. Fire Extinguisher:				
	A	Total numbers	21 nos.	21 nos.
	B	Types	ABC/CO ₂	ABC/CO ₂
	C	ISI marking	ISI Marked	ISI Marked
06. First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.
	B	Length of hose reel hose	30 m	30 m
	C	Nozzle diameter	5 mm	5 mm
07. Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A
	B	Location of main panel	N/A	N/A
	C	Location of repeater panel	N/A	N/A
	D	Alternate source of power	N/A	N/A
	E	Hooters	N/A	N/A
08. MOEFA:			N/A	Provided
09. Public Address System:			N/A	Provided
10. Automatic Sprinkler System:				
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A
11. Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A
	C	Hose box	N/A	N/A
12. Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A
	B	Hose box	N/A	N/A
13. Pumping Arrangements:				
1	Ground level			
	A	Discharge of main pump	N/A	N/A
	B	Head of main pump	N/A	N/A
	C	Number of main pumps	N/A	N/A
	D	Jockey pump out put	N/A	N/A
	E	Jockey pump head	N/A	N/A
	F	Standby pump out put	N/A	N/A
	G	Standby pump head	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A
	I	Pump house access	N/A	N/A
2	Terrace Level			
	A	Discharge of pump	450 LPM	450 LPM
	B	Head of the pump	40 m	40 m
	C	Power supply	Required	Provided
	D	Auto starting of pump	N/A	N/A

N/15

Rajkiya Pratibha Vikas Vidyalaya, B-Block Yamuna Vihar, Delhi-110053.

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 litr. ✓	10,000 litr. ✓	MR
15. Exit Signage:		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:		NA	N/A	N/A
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:		NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/2019/2663 dated 07/05/2019 has been rectified.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2014/NDZ/213 dated 11/02/2014 under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 is recommended to be renewed.

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO/Laxmi Nagar

D.O / EAST

14.7.2015
C.F.O. / 15/07/25
Principal Director
22/7/2015
C.F.O. / 22/07/25
P.T.O.