

C/44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/MN/Metro/2025/ 75

Dated: 14/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Rajouri Garden Metro Station (Line No. 03) Located at Rajouri Garden Metro Station (Line No. 03) New Delhi, comprised of Basement + Ground + Concourse & Platform (Except PD Area), was issued FSC vide Letter No. F6/DFS/MS/MN/Metro/2022/143 dated 01/04/2022. The premises was re inspected by the officer concerned of this department on 07/02/2025 in the presence of Sh. Sudhanshu (AM Fire) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D sub Division D- with effect from 14/02/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 14/02/2025 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per BBL-1983.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. All Exits & Passage lead to ground should be kept from any obstruction.

INSPECTION REPORT

| | | |
|-----|---|---|
| 1. | Name & address of the building | Rajouri Garden Metro Station Line No.03, Located at Rajouri Garden Metro Station Line No.03, New Delhi. |
| 2. | Type of Occupancy | Assembly |
| 3. | Type of Case | Renewal (Basement, Ground, Concourse & Platform (Except PD Area) |
| 4. | Details of previous NOC | F6/DFS/MS/MN/Metro/2022/143 dated 01/04/2022 |
| 5. | Fire Safety directives letter No | Nil |
| 6. | Date of inspection | 07/02/2025 |
| 7. | Name of the Inspecting Officers | Sarabjeet Singh ADO (MN) |
| 8. | Name and designation of officers from the building side | Sh. Sudhanshu (Am Fire) |
| 9. | Year of Construction | 2005 (As per previous Inspection Report dated 21/03/2022) |
| 10. | Applicant's letter No. | Outdoor dairy No. 10965 dated 03/01/2025 |

The said building comprised of Basement, Ground, Concourse & Platform (Except PD Area).

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Required as per Rule 35(6) of DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|--------|---|---|------------------|----------------|
|--------|---|---|------------------|----------------|

1 Access to building

| | | | | |
|--|--------------------------|--------------|--------------|----|
| | • Road width | On Main Road | Provided | MR |
| | • Gate width | 05 mtr | On Main Road | MR |
| | • Width of internal road | NA | NA | NA |

2 Number, Width, Type & Arrangement of Exits

| | | | | | | |
|-------------------------|--|--|----------|----|--|--------------|
| a. Number of staircases | <ul style="list-style-type: none">• Upper Floors• Basements | 02 | Provided | MR | | |
| | | 02 | Provided | MR | | |
| | b. Width of staircases | <ul style="list-style-type: none">• Upper Floors• Basements | 2 m | | G to LC=2x4.1m(P-1) & 4.1m, 4.2m(P-2) LC to UC=4m, 4.1m P-1 & 4.65m, 4.7m(P-2) UC to P=4x4.1m(2 for each platform) | MR(old case) |
| | | | Required | | Provided | MR(old case) |
| | c. Protection of exits | <ul style="list-style-type: none">• Fire check door• Pressurization | NA | | NA | NA |
| | | | NA | | NA | NA |
| | e. No. of continuous staircases to terrace | | NA | | NA | NA |
| | f. Width of Corridor | | Old Case | | Provided | MR |
| | g. Door Size | | 2 m | | Provided | MR |

3 Compartmentation.

| | | | | |
|--|--------------------------------|----------|----------|----|
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | Required | Provided | MR |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |

4 Smoke Management System.

| | | | | |
|--|----------------|----------|----------|----|
| | • Basements | Required | Provided | MR |
| | • Upper floors | NA | NA | NA |

5 Fire Extinguishers

| | | | | |
|--|-----------------|----------------------------|----------|----|
| | • Total numbers | 35 nos. | Provided | MR |
| | • Types | CO ₂ , ABC type | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |

6 First-Aid Hose Reels.

| | | | | |
|--|-------------------------------|----------------|----------|----|
| | • Total numbers on each floor | 2 (at each PF) | Provided | MR |
| | • Length of hose reel hose | 30 mts | Provided | MR |
| | • Nozzle diameter | 05 mm | Provided | MR |

| | | | | |
|----|--|---|---------------------|----|
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | Smoke | Provided | MR |
| | • Location of Main Panel | Required | Provided | MR |
| | • Location of Repeater Panel | Required | Provided | MR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Required | Provided | MR |
| 8 | MOEFA | Smoke | Provided | MR |
| 9 | Public Address System. | Required | Provided | MR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | 150 mm | Provided | MR |
| | • Number of hydrants per floor | 02 (on each PF) | Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | 02 | Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | All the pumps are connected are generator also | | |
| | ➤ Discharge of main Pump | 1800 LPM | Provided | MR |
| | ➤ Head of Main pump | 60m | Provided | MR |
| | ➤ Number of main pumps | 01 | Provided | MR |
| | ➤ Jockey Pump out put | 180 LPM | Provided | MR |
| | ➤ Jockey pump head | 60m | Provided | MR |
| | ➤ Standby Pump out put | 1800 LPM | Provided | MR |
| | ➤ Standby Pump Head | 60m | Provided | MR |
| | ➤ Auto Starting/ Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | 50,000 ltrs | Provided | MR |
| | ➤ Draw-off connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | NA | 10,000 ltr provided | NA |
| 15 | Exit Signage. | Required | Provided | MR |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | Required | Provided | MR |
| | • Fireman's Grounding Switch | Required | Provided | MR |
| | • Lift Signage | Required | Provided | MR |
| 17 | Standby power supply | Required | Provided | MR |

| | | | | |
|----|--|--|----------|----|
| 18 | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | Required | Provided | MR |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | Required | Provided | MR |
| | • Battery backup | Required | Provided | MR |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Co ₂ Flooding for ASS, HT & LT Pannel | Provided | MR |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOO vide letter no F6/DFS/MS/MN/Metro/2022/143 dated 01/04/2022 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

1mno
2025

24/02/2025

10/2/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

10/2/2025

11/2/2025
Director

11/2/2025

Sir, F.T is put up for your kind personal & Signature please.

13/2/2025

Director

546400
Dated: 10/2/2025