

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/BNQT/2025/SZ/ 73
To

Dated: 01/05/2025

The Addl. Commissioner of Police,
Lic Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Rajwada Banquet (A Unit of GK Food India)
at Plot No 1A, Star City Mall, Mayur Vihar Ph-I, New Delhi 110091

Sir,

This has reference to your **MCD Portal ID 2025040105132 dated 01/04/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 12.04.2025 in the presence of Mr. Vinay Aggarwal to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Rear side exit gate found blocked.
2. Automatic detection system found removed at some area in banquet hall.
3. MOEFA found removed at some locations of banquet hall.
4. Automatic sprinkler System found removed at some area in banquet hall.
5. Exit signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

9/5/25