



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

257
7/6
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/NDZ/BNQT/2025/41

Dated: 04/07/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Rajwada Banquet (A Unit of GK Food India) at Plot No. 1 A at grade level in Star City Mall Mayur Vihar Ph-1, Delhi-110091 comprises of Basement + Ground + Two upper floors only (Banquet Hall at ground floor only) owned /occupied by M/s Rajwada Banquet, was granted FSC vide letter No. F6/DFS/MS/BNQT/NDZ/2022/42 dated 05/08/2022. The premises was re-inspected by the officer concerned of this department on 26.06.2025 in the presence of Mr. Vinay Aggarwal and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "Assembly Building" Class Group - D with effect from 04/07/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 and also conditions printed below.

Issued 04/07/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, MCD, Civic Center, J.L.N. Marg New Delhi - 110002: with a request to ensure the occupancy as detailed above and deviation if any.
2. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi - 110024 w.e.f. - MCD portal ID - 2025061710146 dated 17/06/2025.
3. The Owner, M/s Rajwada Banquet (A Unit of GK Food India) at Plot No. 1A at grade level in Star City Mall Mayur Vihar Ph-1, Delhi-110091.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for ground floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Rajwada Banquet (A Unit of GK Food India) at Plot No. 1A, Star City Mall Mayur Vihar Ph-1, Delhi-110091.		
2	Building is comprised of	Basement plus Ground plus two upper floors. (Banquet Hall at ground floor only)		
3	Type of occupancy	Assembly Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/BNQT/NDZ/2022/42 dated 05/08/2022		
6	Fire safety direction letter no.	F6/DFS/MS/NDZ/2024/696 date 27/11/2024		
7	Date of inspection	26/06/2024		
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)		
9	Name of the designation of officer From the building side	Mr. Vinay Aggarwal		
10	Year of construction	2006		
11	Applicant's letter no	MHA Portal application No. 2025061710146 dated 17/06/2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Old Noc directive letter	Provided at Site	Remarks MR/NMR
1	Access to building			
	a Road width	12 mtrs.	13 mtrs.	MR
	b Gate width	N/A	N/A	N/A
	c Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	A Number of staircases	Common for star city mall building		
	a Upper floor	N/A	N/A	N/A
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	N/A	N/A	N/A
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	2.0 mtrs. & 1.50 mtr.	2.0 mtrs. & 1.50 mtr.	MR
3	Compartmentation			
	a Fire check door	N/A	N/A	N/A
	b Sealing of electrical shafts	Required	Sealed	MR
	c Fire rating of shaft door	N/A	N/A	N/A
	d Water curtain	N/A	N/A	N/A
	e Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	a Basement	N/A	N/A	N/A
	b Upper floor	Required	Provided	MR

②A

M/s Rajwada Banquet (A Unit of GK Food India) at Plot No. 1A, Star City					
5.	Fire Extinguisher				
	a	Total numbers	04 nos.	06 nos.	MR
	b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels. Common for star city mall building				
	a	Total numbers	02 nos.	Provided	MR
	b	Length of hose reel hose	30 mtrs.	Provided	MR
	c	Nozzle diameter	05 mm	Provided	MR
7	Automatic fire detection and alarming system.				
	a	Type of detectors	Required	Provided	MR
	b	Location of main panel	Required	Provided	MR
	c	Location of repeater panel	Required	Provided	MR
	d	Alternate source of power	Required	Provided	MR
	e	Hooter's location	Required	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public address System.		Required	Provided	MR
10	Automatic Sprinkler System.				
	a	Basement	N/A	N/A	N/A
	b	Upper floors	Required	Provided	MR
	c	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants Common for star city mall building				
	a	Size of riser	Required	Provided	MR
	b	Number of hydrants per floor	02 no.	Provided	MR
	c	Hose Box	02 no.	Provided	MR
12	Yard Hydrants. Common for star city mall building				
	a	Total number of hydrants	Required	Provided	MR
	b	Hose Box	Required	Provided	MR
13	Pumping Arrangements. Common for star city mall building				
	A	Ground Level			
		a	Discharge of main Pump	4500 LPM	4500 LPM
		b	Head of Main Pump	50 mtrs	50 mtrs
		c	Number of main pumps	02 nos.	02 nos.
		d	Jockey pump out put	450 LPM	450 LPM
		e	Jockey pump head	50 mtrs	50 mtrs
		f	Standby pump out put	4500 LPM	4500 LPM
		g	Standby pump head	50 mtrs.	50 mtrs.
		h	Auto starting /manual stopping	Required	Provided
		i	Pump House Access	Required	Provided
	B	Terrace Level		All above pumps are provided at terrace	
		a	Discharge of pump	N/A	N/A
		b	Head of the Pump	N/A	N/A
		c	Power supply	N/A	N/A
		d	Auto Starting of pump	N/A	N/A

M/s Rajwada Banquet (A Unit of GK Food India) at Plot No. 1A, Star City Mall Mayur Vihar Ph-1, Delhi-110091

14	Captive Water Storage for Fire Fighting.				
	Common for star city mall building				
	a	Underground tank capacity	2,00,000 liters	Provided	MR
	b	Draw-off connection	Required	Provided	MR
	c	Fire service inlet	Required	Provided	MR
	d	Access to tank	Required	Provided	MR
	e	Overhead Tank capacity	2,50,000 liters	Provided	MR
15	Exit Signage.				
16	Common for star city mall building				
	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	Required	Provided	MR
	d	Firemen's grounding switch	Required	Provided	MR
	e	Lift Signage	Required	Provided	MR
17	Standby power supply				
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:				

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/BNQT/2025/SZ/73 dated 01/05/2025 by this department has been rectified by the management.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/BNQT/NDZ/2022/42 dated 05/08/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

D.O.E.D. *Approved*
27/06/2025

By C.F.O. (NDZ) *28/06/25*

C.F.O. *at 11/2025*

Director
21/06/25

ADY

P.S.D