



75  
Azadi Ka  
Amrit Mahotsav C-26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/531

Dated: 18/06/2025

To

The Principal,  
Pt Ram Chander Vidhya Niketan,  
Village Bharthal,  
New Delhi-110077

**Sub: Renewal of Fire Safety Certificate in r/o Pt Ram Chander Vidhya Niketan located at VPO Bharthal, Dwarka Sector-26, New Delhi-110077**

Sir,

Please refer to your letter No. 1757450 dated Nil received through Outdoor diary No. 1688 dated 15/05/2025, on the subject cited above. In this connection, it is to inform you that the school premise was visited by the officer concerned of this department on 05/06/2025 in the presence Mr. Gaurav Malik (Care taker) to verify the availability and operability of fire protection systems. During the inspection, the shortcomings observed are as below.

1. One of the staircases found blocked on second floor.
2. First aid hose reel found provided but non-functional.
3. Internal hydrant found non-functional and hose-box empty.
4. Terrace level fire pumps provided found non-functional.
5. Exit signage's found removed at some locations.

In view of above, application for renewal of fire safety certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054