



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

C-36
एक कदम स्वच्छता की ओर

No. F.6/DFS/MS/School/2025/SZ/1212

Dated: 30/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Ram Chandra Sanatan Dharam Modern Public Senior Secondary School, Gali No. 8, Sadh Nagar, Palam Colony, New Delhi-110045, comprised of Ground + 01 upper floors, was issued FSC vide this department letter No. F6/DFS/MS/SZ/2022/School/315 dated 25/03/2022. The premise was re-inspected by the officer concerned of this department on 19/09/2025 in the presence of Smt. Seema Rani (Principal) and found that said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school premise/building is fit for occupancy class "Educational Group B" with effect from 30/09/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/09/2025 at New Delhi by


29/9/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
dfg

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. Principal, Ram Chandra Sanatan Dharam Modern Public Senior Secondary School, Gali No. 8, Sadh Nagar, Palam Colony, New Delhi-110045

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1.	Name & address of the building	Ram Chandra Sanatan Dharam Modern Public Senior Secondary School , Gali No. 8, Sadh Nagar, Palam Colony, New Delhi-45		
2.	Type of occupancy	Educational, Group-B (School)		
3.	Building comprised of	Ground plus one upper floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/SZ/2022/School/315 Dt. 25/03/2022		
6.	Fire safety directives letter No.	DOE Circular 262 – 362 dated 17/01/2005		
7.	Date of Inspection	19/09/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side.	Smt. Seema Rani (Principal)		
10.	Year of construction	2006		
11.	Applicant's letter No.	No. RCSD/PLM/2024-25/26 dated 18/08/2025 Outdoor Diary No. 5069 dated 21/08/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	OLD NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	➤ Upper floors	2 Nos	Provided	MR
	➤ Basements	N/A	N/A	N/A
	b. Width of staircases			
	➤ Upper floors	1.5m / 0.75m	1.40m & 1.21m	MR (Old Case)
	➤ Basements	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.5 m	1.75 m	MR
	f. Door Size	1.0 m	1.0m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers at each floor	02 per floor	08 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	One	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR

N-18

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements:			
	• Ground Level			
	➤ Discharge of main pump	Required	180 LPM	MR
	➤ Head of main pump	30 mtr	30 mtr	MR
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2,500 ltrs	Provided	MR
15.	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply			
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A


N-19


19.	Fire Control Room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A		N/A
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Required	ABC type fire extinguisher provided near elect. meter	MR


The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/ SZ/2022/School/315 dated 25/03/2022, **renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.**



Accordingly, DFA is put up for approval & signature please.




Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (DWK)

DO (SW) 
24/9/25


CFO 
24/9/2025

Principal Director

CFO to 

25/09/25

 26/9
DO (SW)
ADO (DWK)
CFO 
26/9/2025

Sir, F.T Uthra is putting for your Sing. M

CFO/HB 
MS 29/9


20/09/25