

C-14

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2025/155

Dated: 13/03/2025

To

The Principal,
Ramjas Primary School,
Baradari, Ballimaran, Delhi - 06.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Ramjas Primary School, Baradari, Ballimaran, Delhi - 06.

Sir,

This has reference to your letter outdoor diary No. 12692 dated 20.02.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 07.03.2025 in the presence of Mrs. Anu Vashisth (Principal) and it was observed that building is comprised of ground & 02 upper floors and have complied the shortcomings issued vide letter no. F6/DFS/MS/2015/School/982 dated 15.05.2015 except following which still exists.

1. The school building is not accessible to fire engine as the width of road is less than 06 mtrs.
2. Hose reel hose not provided in the building.
3. Fire pump capacity of 450 LPM not provided.
4. Overhead water tank capacity of 10,000 ltrs. not provided.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000
o/c
10/03/25

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi.