

251

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2025 | 24

Dated:-13.01/2025

To,

The Manager
M/S Raman Palace Guest House,
1310-1311- A, Sangatrashan Bazar,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o Raman Palace Guest House at 1310-1311- A, Sangatrashan Bazar, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024122618432 dated 26/12/2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 03/01/25 in the presence of Manager and following shortcomings were observed:

1. CO-detector found non functional.
2. Pump found nonfunctional and not provision of auto mode start is not available.
3. Stand by power supply found nonfunctional.
4. Section/elevation of building plan is also required to be uploaded on the portal.

In view of above, the Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. Addl. Commissioner of Police (Lic), 1st floor, Defence Colony Police Station, New Delhi.