

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

Dated: 07/04/2025

No. F6/DFS/MS/2025/School/WZ/ 448

**FIRE SAFETY CERTIFICATE**

Certified that the **Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp, Sector-21) Kirari, Rohini, Delhi-110085**, comprised of **Two Blocks, Gr.+01 & Gr.+02 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/School/WZ/336 dated 29.03.2022**. The premises was re-inspected by the officer concerned of this department on **28.03.2025** in the presence of **Mr. Sunil Kumar (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from **07/04/2025** for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/04/2025 at New Delhi by

  
(Atul Garg)  
**DIRECTOR**  
Ph; 011-23414000

Copy to :-

1. The Director of Education, Old Secretariat, Delhi
2. The Principal, Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp, Sector-21) Kirari, Rohini, Delhi-110085.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

**INSPECTION REPORT**

1. Name & address of the building : Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp Sector-21) Kirari, Rohini, Delhi-110085.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Two Blocks, Gr.+01 & Gr.+02 upper floors)
4. Details of Previous NOC : F.6/DFS/MS/2022/School/WZ/336 dated 29.03.2022
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 28.03.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers  
From the building side : Sh. Sunil Kumar (Owner)
9. Year of Construction : 2002 & 2011
10. Applicant's letter No. : Online e-mail dated 03..03.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible 4.5m NA	Accessible 4.0m NA	MR MR(old case) NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	d. Number of staircases	02nos.	03nos.	MR
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	-NA-	-NA-	-NA-
	e. Width of staircases	1.5m	Gr.+2-1.60m Gr.+1-1.30m & 1.48m	MR(old case)
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	-NA-	-NA-	-NA-
	f. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	Gr.+2-1.05 to 1.12m Gr.+1-1.0m	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	-NA- 12 a/c per hour	-NA- Natural ventilated	-NA- MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	10nos. ABC/CO2 ISI marked	12nos. ABC-12 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01nos. 30mm 5m	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> </ul>	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-



	<ul style="list-style-type: none"> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Ground &amp; Upper Floors</li> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	2 x 450lpm	2 x 450lpm	MR
		40m	40m	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	10,000ltr & 2500 ltr	10,000ltr & 2500 ltr	MR
16.	<b>Provision of Lifts.</b>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	<b>Standby power supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

N/25

**Special Fire Protection System for Protection of special Risks, if any:**

-NA-

-NA-

-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2022/School/WZ/336 dated 29.03.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*[Signature]*  
11/4/25

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

DO (NW)

*[Signature]*  
01/04/2025

*[Signature]*  
By G.S. (WZ)

*[Signature]*  
02/4/2025

DOFO/... 11/2 NW  
2/4/2025

*[Signature]*

*[Signature]*  
3/4/2025

Director

*[Signature]*  
3/4/25

*[Signature]*  
Ay Kar

FT letter to put up for kind perusal & signature please.

*[Signature]*  
6/4/25

*[Signature]*  
Director  
11/4/25  
W