



FIRE SAFETY CERTIFICATE

Certified that the **Rani Jhansi Sarvodaya Kanya Vidyalaya (Morning shift)/ Sarvodaya Bal Vidyalaya (Evening shift)** located at **Railways Colony, Tughlakabad, New Delh-44** was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/School/2021/SZ/202 dated 10.03.2021 & F6/DFS/MS/School/SZ/2022/1010 dated 15.09.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 17.06.2025 in the presence of Dr. Leena Asthana (HOS/Vice Principal) and found that the school building is comprised of three blocks: A, B & C block - Each block having Ground + 03 upper floors. The building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building is fit for occupancy of **Group B "Educational Building"** with effect from 20/06/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 20/06/2025 at New Delhi by.


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Rani Jhansi Sarvodaya Kanya Vidyalaya (Morning shift)/ Sarvodaya Bal Vidyalaya (Evening shift) located at Railways Colony, Tughlakabad, New Delh-44.

Conditions for the validity of Fire Safety Certificate:-

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

2/22

INSPECTION REPORT					
1	Name and address of the building:		Rani Jhansi Sarvodaya Kanya Vidyalaya (Morning shift)/ Sarvodaya Bal Vidyalaya (Evening shift) located at Railways Colony, Tughlakabad, New Delhi-44. School ID no. 1925031 (Morning shift) School ID no. 1925017 (Evening shift)		
2	Building is comprised of		Comprised of Three blocks A block- Ground + 03 upper floors B block- Ground + 03 upper floors C block- Ground + 03 upper floors		
3	Type of occupancy		Educational Building (Group -B)		
4	Type of case:		Renewal		
5	Details of previous FSC:		F6/DFS/MS/School/2021/SZ/202 dated 10.03.2021 & F6/DFS/MS/School/SZ/2022/1010 dated 15.09.2022		
6	Fire safety directives no.:		Nil		
7	Date of inspection:		17.06.2025		
8	Name of the inspecting officer:		ADO Rajesh Kumar Shukla (M. Road)		
9	Name and designation of the officer from the building side:		Dr. Leena Asthana (HOS/Vice Principal)		
10	Year of construction:		1990, 2016 & 2021		
11	Reference letter no.:		Outdoor diary no.2548 dated 09.06.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		Requirements as per Rules 35 (6)	Provide at site	Remarks MR/NMR
1	Access to Building				
	A	Road width	6.0 mtrs.	6.0 mtrs.	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	A block - 3 nos. B block - 4 nos. C block - 3 nos.	A block - 3 nos. B block - 4 nos. C block - 3 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the staircase:			
		a) Upper floor	1.50 m each block	A block - 1.50 m each B block - 1.50 m each C block - 1.70 m each	MR
		b) Basements	NA	NA	NA
	C	Protection of exits			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	2 nos. each block	Provided	MR
	F	Width of the corridor	1.5 m each block	Provided	MR
	E	Door size	1.0 mtrs. (for class room)	1.0 mtrs. (for class room)	MR
3	Compartmentation:				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Upper floors	NA	NA	NA
	B	Basements	NA	NA	NA
5	Fire Extinguishers				
	A	Total numbers	75 nos.	80 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	Required	Provided	MR

N/28

6	First Aid Hose reel			
	A	Total no. at each floor	A block - 2 nos.	A block -2 nos. MR
	B	Length of hose reel	B block - 4 nos.	B block - 4 nos. MR
	C	Nozzle diameter	C block - 4 nos.	C block - 4 nos. MR
7	Automatic Fire Detection and Alarm System (ADAS)			
	A	Type of detectors	NA	NA NA
	B	Location of main panel	NA	NA NA
	C	Location of repeater panel	NA	NA NA
	D	Alternate power source	NA	NA NA
	E	Hooter's location	NA	NA NA
8	MOEFA			
9	Public Address System			
			NA	NA
10	Automatic Sprinkler System			
	A	Basement	NA	NA NA
	B	Upper floor	NA	NA NA
	C	Sprinklers above false ceiling	NA	NA NA
11	Internal Hydrants			
	A	Size of the riser/down comer	NA	NA NA
	B	No. Of hydrants per floor	NA	NA NA
	C	Hose box	NA	NA NA
12	Yard Hydrants			
	A	Total no. of hydrants	NA	NA NA
	B	Hose box	NA	NA NA
13	Pumping Arrangements			
	A	Ground Level		
		a) Discharge of main pump	NA	NA NA
		b) Head of main pump	NA	NA NA
		c) Number of main pump	NA	NA NA
		d) Discharge of jockey pump	NA	NA NA
		e) Head of jockey pump	NA	NA NA
		f) Discharge of standby pump	NA	NA NA
		g) Head of standby pump	NA	NA NA
		h) Auto starting/ manual stopping	NA	NA NA
	B	Terrace Level		
		a) Discharge of terrace pump	450 LPM each block	2 nos. of 450 LPM each block MR
		b) Head of terrace pump	40 m each	Provided MR
		c) Alternate power supply	Required	Provided MR
		d) Auto starting of pump	Required	Provided MR
14	Captive Water Storage for Fire Fighting			
	A	Underground tank capacity	NA	NA NA
	B	Draw off connection	NA	NA NA
	C	Fire service inlet	NA	NA NA
	E	Access to tank	NA	NA NA
	D	Overhead tank capacity	NA	NA NA
15	Exit Signage			
		10,000 litters each block	Provided	MR
16	Provision of lift			
	A	Pressurization of lift shaft	NA	NA NA
	B	Pressurization of lift lobby	NA	NA NA
	C	Communication in lift car	NA	NA NA
	D	Fireman switch	NA	NA NA
	E	Lift signage	NA	NA NA
17	Standby Power Supply			
			NA	NA NA

BL

N/24

Rani Jhansi Sarvodaya Kanya Vidyalaya (Morning shift)/ Sarvodaya Bal Vidyalaya (Evening shift) located at Railways Colony, Tughlakabad, New Delh-44.

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided But Not Functional (PNF).

Note: The four Blocks detailed in the inspection report at N-15 have now been converted in Two Blocks by merging the three blocks and keeping a separate block. An additional New Block (SPS Construction) had been separately issued Fire Safety Certificate (FSC) vide letter no. F6/DFS/MS/School/SZ/2022/1010 dated 15.09.2022. Presently the school has three blocks (Namely A, B & C blocks) as mentioned and inspection has been conducted for all the blocks thereby proposing a single FSC for the entire school.

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

If agreed to the note above & in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule, the FSC issued vide letter no.F6/DFS/MS/School/2021/SZ/202 dated 10.03.2021 & F6/DFS/MS/School/SZ/2022/1010 dated 15.09.2022 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

[Signature]
17/6/25
Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (M. Road)

DO (SD) *[Signature]* 18/6/25

CFO *[Signature]* 19/6/25

Director *[Signature]* 19/6/25

[Signature]

[Signature]