



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 60

Dated: 24/01/2025

To

Sh. Vikas Yadav (Owner),  
Rao Mansa Ram Public School,  
Plot No. 991/1, Near Oberoi Farm,  
Kapashera, New Delhi-110097

**Sub: Renewal of Fire Safety Certificate in respect of Rao Mansa Ram Public School located at Plot No. 991/1, Near Oberoi Farm, Kapashera, New Delhi-110097**

Sir,

This has reference to the email dated 17/12/2024 received from mail Id. [raomansarampublicschool4007@gmail.com](mailto:raomansarampublicschool4007@gmail.com), on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 13/01/2025 in the presence of Ms. Razia Sultan (Accountant) from fire safety and means of escape point of view. During the inspection, the shortcomings observed are as below.

1. Hose reel hose provided found non-functional/damaged.
2. Terrace fire pump was not on auto mode.
3. Exit signage found removed at some places.

In view of the above, the application for renewal of fire safety certificate is rejected. You are requested to rectify the shortcomings above under intimation to this department for further action. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054