



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-29
संख्या: २७११/२०२५
दिनांक: २७/११/२०२५

No: F.6/DFS/MS/2025/WZ/ 855

Dated: 27/11/2025

To,

The Manager,
Rao Sher Singh Memorial Public School,
J-31/1, Shiv Ram Park, Nilothi More,
Nangloi, Delhi-110041.

Sub:- Renewal of Fire Safety Certificate in respect of Rao Sher Singh Memorial Public School located at J-31/1, Shiv Ram Park, Nilothi More, Nangloi, Delhi- 110041.

Sir,

This has reference to your letter no. R.S.S./3028/11/025 dated 06/11/2025 received through outdoor diary no. 7889 dated 06/11/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 15.11.2025 to see the compliance of the requisite fire safety measures. Smt. Meenakshi Sharma was present at the time of inspection.

During the course of inspection it was observed that the school building is comprised of Ground and First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Fire extinguishers found provided but not functional.
2. First aid hose reels found provided but not functional.
3. Terrace level pump found provided but not functional.
4. Overhead tank of 2000 ltrs capacity found provided against the required capacity of 2500 ltrs.
5. Exit signages found removed at some places.


You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


27/11/25

(S.K. Dua)

Dy. Chief Fire Officer
West Zone



Copy to :-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.