

cl/109

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/Hospital/SZ/2025/ 90

Dated: - 16/01/2025

To,

The Assistant Engineer (Elect.)
PWD HMESD South West- I,
Dada Dev Hospital, Nasirpur, New Delhi-110045.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o. M/s Rao Tula Ram Memorial Hospital situated at Jaffarpur, New Delhi-110073.

Sir,

Please refer to your letter dated 23.12.2024 received through online email Id aeepwddelhihsw02@gmail.com, on the subject cited above. In this connection it is to inform you that the above said Hospital building have been inspected by the officer concerned of this department, in presence of AE, Elect. (PWD), on dated 08.01.2025, to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/Hospital/2024/SZ/638 dated 25.11.2024. During the course of inspection, it was observed that the shortcomings are not fully complied except shortcoming No. 4.

In view of the above, renewal of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running hospital in absence of requisite fire safety arrangements shall be at the risk & liability of the hospital management.

Yours faithfully

(Atul Garg)
Director
Delhi Fire Service

Copy for information: -

1. The Medical Superintendent, M/s Rao Tula Ram Memorial Hospital, Jaffarpur, New Delhi-110073.
2. The Directorate of Health Services, M.O./C Nursing Home Cell, S-1, School Block, Shakarpur, New Delhi-110092.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 638

Dated: 25/11/2024

To,

The Medical Superintendent,
M/s Rao Tula Ram Memorial Hospital,
Jaffarpur, New Delhi-110073.

Sub: - Regarding renewal of Fire Safety Certificate in r/o. M/s Rao Tula Ram Memorial Hospital situated at Jaffarpur, New Delhi-110073.

Sir,

This has reference to your Letter No. Form 'J' dated Nil, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital building on dated 14.11.2024 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Dr. Anil Yadav (CMO) & Sh. Sita Ram Meen (PWD) was present and it was observed that the hospital building is comprised of ground plus two upper floors and have following shortcomings.

1. Four Porta Cabins constructed at roof of first floor needs to be removed.
2. Passage found blocked in front of OT.
3. Staircases found blocked near wards.
4. Fire-fighting system may be extended to Oxygen plant and manifold room.

Keeping in view of above, renewal of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service
9/11/24

Copy to: -

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.