



c-6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/NDZ/EH/2025/223

Dated: 19/05/2025

To,

The Joint Commissioner of Police (Lic.),
1st floor Police Station Defence Colony,
New Delhi

Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Rebel Foods Private Limited, Shop No.-03, G/F, MCD No. 6045, 9UB Bungalow Road Jawahar Nagar New Delhi-110007.

Sir,

This has reference to MCD application ID No. 2025041106160 dated 17/04/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned Eating House from fire safety point of view on dated 10/05/2025 in presence of **Mr. Nandan kumar Manager**. The building comprised of ground two upper floors but Eating House is running ground floor only. The following shortcoming was observed during the time of inspection.

1. Two doors of width 01 meter & 0.68 meter (2nd exit passing through the kitchen) are provided against requirement of two separate exit doors 1.50 meter each.
2. Kitchen should be segregated by the means of fire check door.
3. First aid hose reels not provided.
4. MOEFA not provided.
5. Terrace pump capacity 450 lpm head 40 meters not provided.
6. An over head tank capacity 20,000 liters not provided.
7. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit..

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

2. 19/5/25