

c/48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/NDZ/2025/ 156

Dated: 09/04/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: Regarding renewal of fire safety certificate in respect of Red Chilli (A unit of Maag Entertainment Pvt. Ltd.), located at S-15, Ground Floor, Green Park Extn, Green Park, Delhi-110016.

Sir,

Please refer to your online application no. 2025031303506 dated 13/03/2025, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 29/03/2025 in the presence of Sh. Harish Kumar (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Ground Floor only in a building comprised of Basement + Ground + 02 Upper Floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. There are two exits door main entry is 120 cm against the required width of 1.50 mtr each respectively.
2. First Aid Hose reels are provided but not functional.
3. 900 LPM pump provided but not automode.
4. Exit signage are found removed.
5. Inspection Ladder is found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, South Zone, green Park, Delhi-110016.
2. The Owner/Occupier, Red Chilli (A unit of Maag Entertainment Pvt. Ltd.), located at S-15, Ground Floor, Green Park Extn, Green park, Delhi-110016.