



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/NDZ/2025/ BNQT 113

Dated:-

18/06/2025

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi -110002.

Sub.:- Regarding issuance of Fire Safety Certificate in respect Red Coral Hospitality located at Shop No. G-25 to G-29, Ground Floor, Cross River Mall, Karkardooma, Shahdara, Delhi-110092

Sir,

This has reference to online application no. 2025052609128 dated 27/5/2025 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 09/06/2025 in the presence of Kuldeep Bhadauria (Owner) to check the compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/BNQT/NDZ/2024/75 dated 05/06/2024.

During inspection, it has been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Authorized Signatory, Red Coral Hospitality, Shop No. G-25 to G-29, Ground Floor, Cross River Mall, Karardooma, Shahdara, Delhi-110092.



No. F6/DFS/MS/BNQT/NDZ/2024/ 75

Dated: 05/06/2024

To,

Mr. Kuldeep Bhadauria (Owner),
Red Coral Hospitality
Shop no. G-25 & G-29,
Cross River Mall, CBD Ground,
Shahdara, Delhi - 110032.

Sub: - Regarding grant of Fire Safety Certificate in r/o Red Coral Hospitality located at Shop no. G - 25 & G - 29, Cross River Mall, CBD Ground, Shahdara, Delhi -110032.

Sir,

This has a reference to your MHA Application no. 202405106582 dated 08/05/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 30.05.2024 in the presence of Mr. Kuldeep Bhadauria (Owner) and observed that building comprised of two basement + ground + 03 upper floors only. **(Banquet Hall is Ground floor only).**

Following shortcomings were observed during time of inspection:

1. Two Exit doors of width 2.0 meters and 1.05 meters are provided instead of required width of 2.0 & 1.50 meters.
2. Fire check door not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24
w.e.f. - MHA portal ID - 202405106582 dated 08/05/2024.