



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2025/ 251

Dated: 23/05/2025

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Ref: elt.mcdonline application no. 2025050207759

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Relax International Guest House** located at **8225/6, Arakashan Road, Pahar Ganj, New Delhi.**

Sir,

With reference to the elt.mcdonline application no. 2025050207759 on the subject cited above, it is informed that the said guest house was inspected by the officer concerned of this department on. 17.05.2025 in the presence of Mr. Karim (Manager) and following shortcoming were observed at the time of inspection.

1. Hose reel found non functional.
2. CO detector found non functional.
3. Fire pump found non functional.
4. Overhead tank capacity of 2,500 litres has not been provided.
5. Public Address System found non functional.
6. Exit signages found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Service

17/5/25 60 60  
2025