

C/165

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2025/ 111

Dated 17/03/2025

To,

Sh. Ajay Singh Yadav,
Assistant General Manager,
Reserve Bank of India,
6, Sansad Marg, New Delhi.

Sub:- Regarding renewal of FSC in r/o Reserve Bank of India, 6, Sansad Marg, New Delhi.

Sir,

This has a reference to your letter No. DEL.PS.adm.No.S-402/14-04-003/2025-26 dated 30.01.2025, on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 10/03/2025 in the presence of Col. Abhinav, Fire Officer & Major Rita and the following shortcomings were observed:-

1. Detectors are not provided in AHU & sprinklers are required to be extended in rooms/offices at basement.
2. Smoke Management system in basement is not provided.

In view of above shortcomings, the renewal of FSC cannot be issued till the compliance of above said shortcomings.

Yours faithfully

(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

The Chief Architect, New Delhi Municipal Council, Palika Kendra, New Delhi.