



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2026/341

Dated: 21/04/2026

To,

The Commissioner,
 Municipal Corporation of Delhi,
 Civic Centre, Minto Road,
 New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026032003230 dated 20/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 04/04/2026 in the presence of Sh. Ravi Kumar, Owner and following shortcomings were observed: -

1. Public Address System provided but found non-functional.
2. Fire Pump on terrace found removed.
3. Overhead Water Storage tank capacity was 2,000 Ltrs against required capacity of 5,000 Ltrs.
4. Exit Signages found removed.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


 20/4/26

(Dr. S. K. Tomar)
 Chief Fire Officer
 Delhi Fire Service

01C Bp

Copy to: -

1. The Manager, M/s Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Paharganj, New Delhi - 110055.