



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/258

Dated: 22/04/2025

To

The Principal,  
Rising Star Junior School,  
Sector-10, Dwarka,  
New Delhi-110075

Sub: Renewal of Fire Safety Certificate in r/o Rising Star Junior School located at Sector-10, Dwarka, New Delhi.

Sir,

Please refer to your letter No. RSJS/DFS/NOC/2025/61 dated 20/03/2025, received through outdoor diary No. 14753 dated 20/03/2025 on the subject cited above. In this connection, it is to inform you that the above said premise was visited by the officer concerned of this department on 09/04/2025 in the presence of Ms. Monika (Admin) to see the compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/SZ/2022/School/189, dated 21/04/2022 and observed some more shortcomings. Thus, cumulative shortcomings are as below.

1. First aid hose reel found non-functional
2. Terrace level fire pumps not found automatic in operation.
3. Overhead water storage exclusively for firefighting found used for domestic purposes.
4. Basement floor is used for school activities. Class room found constructed and alternate staircase is accessible through class room.

In view of above, application for renewal of fire safety certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter. The occupancy of the building in the absence of valid Fire Safety Certificate shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054