GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 235 Dated: - 11/11/2026

FIRE SAFETY CERTIFICATE

Certified that the Rithala E-Bus Depot, located Near Rithala Metro Station, Delhi-110033, owned/occupied by Rithala E-Bus Depot, has complied with the fire prevention and fire safety requirements in accordance with the directives issued vide Letter No. F.6/DFS/MS/BP/2025/280 dated 14/08/2025. The same was verified by the officer concerned of this department on 07/09/2026 in the presence of Sh. Ankit, A.E. (Electrical), DMRC. This certificate shall remain valid for a period of three years in accordance with Rule 36, unless renewed under Rule 37 or cancelled earlier under Rule 40, and shall be subject to compliance with the conditions stipulated under Rule 38 of the Delhi Fire Service Rules, 2010, as printed below.

Issued on 11/11/2026 at New Delhi by

11/11/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Sh. Pramod Kumar (DGM/Civil/MMI), DMRC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Conditions for validity of Fire Safety Certification: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

-H/B-

INSPECTION REPORT				
1. Name & address of the building	Rithala E-Bus Depot located at Near Rithala Metro Station, Delhi			
2. Type of Occupancy	NA			
3. Type of Case	New Case			
4. Composition of building	NA			
5. Details of Previous NOC	Nil			
6. Fire Safety directives letter No	F.6/DFS/MS/BP/2025/280 dated 14/08/2025			
7. Date of inspection	07/09/2026 & 17/10/2026			
8. Name of Inspecting Officer	ADO (Rohini)			
9. Name and designation of officers From the building side	Sh. Ankit (A.E. Electrical, DMRC)			
10. Year of Construction	2023			
11. Applicant's online application no.	DMRC/CPM-5/OCW-1413/Rithala/2026/3 dated 07/08/2026			

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per directives issued vide letter no. 14/08/2025	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	NA	NA	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	**Compartmentation**			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	a) Basements	NA	NA	NA
	b) Upper floors	NA	NA	NA
5.	**Fire Extinguishers**			
	a) Total numbers	Required	Provided	MR
	b) Types	ABC/CO2	Provided	MR
	c) IS marking	ISI marked	Provided	MR

6.	**First-Aid Hose Reels**			
	a) Total numbers on each floor	NA	NA	NA
	b) Length of hose reel hose	NA	NA	NA
	c) Nozzle diameter	NA	NA	NA
7.	**Automatic fire detection and alarming system**			
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	NA	NA	NA
8.	**MOEFA**	NA	NA	NA
9.	**Public Address System**	NA	NA	NA
10.	**Automatic Sprinkler System**			
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	**Internal Hydrants**			
	a) Size of riser/down-comer	NA	NA	NA
	b) Number of hydrants per floor	NA	NA	NA
	c) Hose Box	NA	NA	NA
12.	**Yard Hydrants**			
	a) Total number of hydrants	Required	10 nos	MR
	b) Hose Box	Required	10 nos	MR
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	2280 LPM	Provided	MR
	➢ Head of Main pump	40 m	Provided	MR
	➢ Number of main pumps	01	Provided	MR
	➢ Jockey Pump out put	180 LPM	Provided	MR
	➢ Jockey pump head	40 m	Provided	MR
	➢ Standby Pump out put	2280 LPM	Provided	MR
	➢ Standby Pump Head	40 m	Provided	MR
	➢ Auto Starting/Manual Stopping	Required	Provided	MR
	➢ Pump House Access	Required	Provided	MR
	Terrace level			
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power Supply	NA	NA	NA
	➢ Auto Starting of pump	NA	NA	NA
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	2.0 lac ltrs.	Provided	MR
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	**Exit Signage.**	NA	NA	NA

N/10

16.	**Provision of Lifts.**			
	a) Pressurization of Lift Shaft	NA	NA	NA
	b) Pressurization of Lift lobby	NA	NA	NA
	c) Communication In lift Car	NA	NA	NA
	d) Fireman's Grounding Switch	NA	NA	NA
	e) Lift Signage	NA	NA	NA
17.	**Standby power supply**	NA	NA	NA
18.	**Refuge Area.**			
	a) Total Area	NA	NA	NA
	b) Location	NA	NA	NA
19.	**Fire Control Room**			
	a) Detector System Panel	NA	NA	NA
	b) Flow Switch Panel	NA	NA	NA
	c) PA System Panel	NA	NA	NA
	d) Battery backup	NA	NA	NA
	e) Building Floor Plans	NA	NA	NA
20.	**Special Fire Protection System for Protection of special Risks, if any:**	3.0 m (mini. Distance after every cluster of 05 buses)	Provided	MR

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate is recommended under Rule 35 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

19/10/2026

Signature of the Inspecting Officer
Name : - Paras Kumar
Designation : - ADO (Rohini)

DO (NW) 21/10

Dy CFO/W2

CFO (W2)

02/11/2026

Debabrata Mukherjee

2/11/26
A.K. MALIK

Pl. see. CFO to

4/11/26

CFO (W2)

5/11/26
A.K. MALIK

10/11/2026

Debabrata Mukherjee

Dy. CFO (W2)

ADO (R)

FT is put up for signature please

APO/Rohini
10/11/2026

CPO/MS

11/11/26
A.K. MALIK

M.S. cell