

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2025/SZ/ 219

Dated 16 / 05 / 2025

To

The Addl. Commissioner of Police,  
Lic/Branch 1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049.

**Sub: -** Regarding issuance of fire safety certificate in r/o M/s RIZQ Restaurant, (A Unit of SHR Hospitality) located at 3<sup>rd</sup> Floor Plot No- D-12 Defence Colony, New Delhi 110024.

Sir,

This has reference to with **MCD Portal ID 2025040305502 dated 19/04/2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.05.2025 in the presence of Mr. Sahil to verify the fire safety measures installed in the building and observed that building is comprised of Basement + Stilt, Ground and 03 upper floors, but restaurant running at Third Floor only. During inspection, following points were observed:

1. The rear side staircase is not communicating to ground level & also one exit door (rear side) found blocked / encroached.
2. First aid hose reel provided but found non- functional.
3. Electrician Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM provided but found non-functional.
4. Terrace level fire fighting pumps capacity 450 LPM provided but found non-functional.
5. Overhead tank capacity 5000 ltrs found empty.
6. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE