



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

10001277
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 458

Dated: 26/05/2025

To,

The Manager,
R.K. Modern Public School
School No. 12/554, Mandoli Extn.,
Gali No.12, Delhi-110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o R.K. Modern Public School located at School No. 12/554, Mandoli Extn., Gali No.12, Delhi-110093.

Sir,

This has a reference to your Outdoor diary No. 14681 dated 19/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 14/05/2025 in the presence of Mr. C.P. Singh (Manager) and observed that building comprised of ground plus one upper floor.

Following shortcomings were observed during time of inspection:

1. One staircase of 0.80 provided against the requirement of two staircase of width 1.50 meter each.
2. First-Aid-Hose Reel Found removed.
3. Fire pump of 220 LPM found removed.
4. Overhead water storage tank of capacity 2500 liters found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to :-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi - 110002.