

c/144

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS//NDZ/2025/ 443

Dated: 17 / 11 /2025

To,

The Manager,
Rockland Guest House,
C-30, Panchsheel Enclave,
New Delhi – 110017.

**Sub: Renewal of Fire Safety Certificate in r/o Rockland Guest House, C-30,
Panchsheel Enclave, New Delhi – 110017**

Sir,

This has a reference to online ID 2025100513964 dated 06/10/2025 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 29/10/2025 in the presence of Deep Krishan, Manager to verify the compliance of the shortcomings issued vide letter No. F6/DFS/MS/NDZ/2025/22 dated 19/03/2025 and observed that the shortcomings are still not complied. (Copy enclosed)

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to comply with the shortcomings under intimation to this department for further consideration in the matter.

Encl.- As above

Yours faithfully,


(A. K. Malik)
Dy. Chief Fire Officer, SZ
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD Civic Center. New Delhi.

C/137

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2025/ 122

Dated:- 19/03/2025

To

The Manager
M/s Rockland Guest House,
C-30, Panchseel Enclave,
New Delhi-110017.

Sub: Regarding issuance of FSC in r/o M/s Rockland Guest House, C-30, Panchseel Enclave,
New Delhi-110017.

Sir,

This has reference to online id no. 2025022802566 dated 28.02.25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 12/03/25 in the presence of Aditya Bhandari and following shortcomings were observed:-

1. CO Detectors is not provided in rooms.
2. Hose reel & pump found nonfunctional.
3. Smoke Management system is not provided.
4. Overhead water tank is provided of 5000 liter against the requirements of 10,000 liter.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.