



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/03

Dated: 03/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Rosary Senior Secondary School** located at **Radio Colony Kingsway Camp, Delhi-110009** comprised of **02 blocks, One block comprised of Ground + 03 upper floors & One block comprised of Ground + 02 upper floors only** owned/ occupied by **Rosary Senior Secondary School** was issued Fire Safety Certificated vide this office letter no. **F6/DFS/MS/School/2021/770 dated 22.09.2021**. The premise was re-inspected by the officer concerned of this department on **28.12.2024** in the presence of **Sh. Anthony (Supervisor)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **"Group B Educational (School)"** with effect from ...**03/01/2025** for a period of **three years**, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ...**03/01/2025** at New Delhi by.

(Atul Garg)  
Director  
Ph: 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Rosary Senior Secondary School located at Radio Colony Kingsway Camp, Delhi-110009.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Rosary Senior Sec. School at Radio Colony, Kingsway Camp, Delhi-110009.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 02 blocks, (A block, Ground+03 upper floors & B block, Ground+02 upper floors)
5. Details of previous NOC : No. F6/DFS/MS/School/2021/770 dated 22.09.2021
6. Fire Safety directives letter No : NBC Part-4
7. Date of inspection :28.12.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Mr. Antony (Supervisor)
10. Year of Construction : 1971, 1984 & 2003
11. Applicant's letter No. : Letter No-RS/2024-25/6972 dated 17.12.2024

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)/Inspection dated 26.11.2012	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	12m	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02nos each block	05nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	A-Block- 1.60m & 1.45m & B-Block- 1.50, 1.55m & 1.50m	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02nos. of each block	A-Block- 01nos & B-Block- 02nos	MR (being old case)
	e. Width of Corridor	1.50m	2.50m	MR
	f. Door Size	01m	1.10m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	25nos	26nos	MR
	• Types	ABC/Co2	ABC--26	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			



	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	02 each block	Provided	MR
		30m	30m	MR
		5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	Size of riser/down-comer	100mm	Provided	MR
	Number of hydrants per floor	02 each block	Provided	MR
	Hose Box	02	02	MR
12	<b>Yard Hydrants.</b>			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	Terrace level			
	➤ Discharge of pump	450 LPM each block	Provided	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	Underground tank capacity	40,000 LTR	Provided	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	Overhead Tank capacity	5,000 LTR for each block	Provided	MR
15	Exit Signage	Required	Provided	MR

16	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	N/A	N/A	N/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>	N/A	N/A	N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/793 dated 28.11.2023.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. F6/DFS/MS/School/2021/770 dated 22.09.2021 under rule 37 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- Asst. Div. Officer (RN)

D.B. Mukharjee (NW)

By cfo 30/12/2024

By cfo (NW)

30/12

cfo 31/12/2024

Director

Asst. Div. Officer (RN)

Conf. P.T.O.