

c/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2025/ 461

Dated: 26/05/2025

To
Ms. Kusumlata Bharadwaj (Principal),
Rosedale School,
A-Block, Budh Nagar, Inderpuri,
New Delhi-110012.

**Sub: Regarding issuance of FSC in r/o Rosedale School, A-Block, Budh Nagar, Inderpuri,
New Delhi-110012.**

Sir,

This has reference to your letter no. nil dated 24.02.2025 & DFS diary no.12923 dated 25.02.2025, on the subject cited above. In this regard, it is to inform you that the matter was examined and observed that this department has already informed you vide letter no.F6/DFS/MS/school/2019/SZ/3156 dated 24/05/2019, wherein it has been informed that required 06 meter road is not available for fire tender movement. Hence, the case cannot be considered for issuance of fire safety certificate till compliance of the shortcoming issued vide aforesaid letter.

Therefore you are request to submit the point compliance of aforesaid letter for further consideration in the matter.

Encl. As above.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Sectt. Delhi - 54.

C-3
c/9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2019/SZ 3156

Dated: 24/05/19

To,

Dr. J D Saxena (President),
Rosedale Education Society,
A-Block, J J Colony,
Inder Puri, New Delhi-110012.

Subject: Regarding issuance of Fire Safety Certificate from Fire safety point of view in r/o Rosedale School, WZ-278/D, A Block, Budhnagar, Inderpuri, New Delhi-110012.

Sir,

This is in reference to your letter no. Nil dated 25.2.2019 on the subject cited above. In this connection, it is to inform you that above said school building have been inspected by the officer concerned of this department on 07.05.2019 in presence of Smt. Kusum Lata (Head of School) to check fire safety arrangements provided in the building as per Circular issued by the Directorate of Education GNCT of Delhi dated 1.3.2011.

During the course of inspection it has been observed that the premise consists of ground and first floor. The following points have been noticed as shortcomings:-

1. The School building is not accessible for fire tenders as width of access road is 2.80 Meters instead of required width 6 Meters.

In view of the above shortcoming fire safety certificate cannot be granted.

Yours Faithfully,

(Atul Garg)

Chief Fire Officer

Copy to:-

1. The Director (Education), GNCT of Delhi, Old Secretariat, Delhi.