

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2025/SZ/240

Dated: 16 / 05 / 2025

To

The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Rosette Guest House at
8708, DBG Road, Pahar Ganj, New Delhi

Sir,

This has reference with **MCD Portal ID 2025040105187 dated 17/04/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 09/05/2025 in the presence of Mr. Ram (Reception) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Electrical meter installed under the staircase is not allowed.
2. Fire check door not provided at ground floor.
3. Smoke Exhaust fan found non-functional.
4. Carbon monoxide detector not working.
5. MOEFA not working.
6. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]
4/5 W.