

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/GH/2025/SZ/ 292

Dated: 16 / 06 / 2025

To

The Joint Commissioner of Police (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Rosette Guest House at  
8708, DBG Road, Pahar Ganj, New Delhi

Sir,

This has reference with **MCD Portal 2025052308957 dated 23/05/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 09/06/2025 in the presence of Mr. Ramu (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Electrical meter installed under the staircase is not allowed.
2. Fire check door not provided at ground floor.
3. Smoke Exhaust fan found non-functional.
4. Carbon monoxide detector not working.
5. MOEFA not working.
6. Exit Signage found removed at some places.

The same observations has already been issued and communicated earlier by this department vide letter of even no 240 dated 16/05/2025.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

de 16/06/2025