

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No.F6/DFS/MS/GH/WZ/School/2025 /347

Dated: 11/08/2025

To,  
✓ The Commissioner MCD,  
Civic Centre, Minto Road,  
New Delhi- 110002.

Sub: Inspection report in r/o M/s. Rossette Guest House, located at Prop.No.8708 DBG Road, Pahar Ganj, New Delhi-110055.

Sir,

With reference to your online application No. 2025071811548 dated 18/07/2025, on the subject cited above. In this connection, it is to inform you that the said premises/building was re-inspected by the officer concerned of this department on 28/07/2025, in the presence of Sh. Vijay Bansal to check the shortcomings already issued by this department vide letter No. F6/DFS/MS/GH/2025/SZ/240 dated 16/05/2025 & F6/DFS/MS/GH/2025/SZ/292 dated 16/06/2025.

However the status of shortcomings are as under.

S. no.	Shortcomings	Status
1.	Electric meter installed under the staircase is not allowed	Not Rectified
2.	Fire check doors not provided at ground floor	Rectified
3.	Smoke exhaust fans found non-functional	Not Rectified
4.	Carbon monoxide detectors are found non- functional	Not Rectified.
5.	MOEFA not working	Not Rectified
6.	Exit signage's found removed at some places.	Rectified

In view of above shortcomings, the application for renewal of fire safety certificate is **rejected**. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully,

  
9/8/2025  
Virendra Singh  
Chief Fire Officer

Copy to: -

1. The Owner/Occupier M/s. Rossette Guest House, located at Prop.No.8708 DBG Road, Pahar Ganj, New Delhi-110055. online application No. 2025071811548 dated 18/07/2025

  
06/8/25