



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



No. F.6/DFS/MS/WZ/EH/2026/ 153

Dated: 28/04/2026

To,

Mr. Raju Patel,
House Plot No.A-36-C, Old No.1, 1st floor,
Block P T, Rajdhani Park,
Delhi-110041.

Sub: Issue of FSC in r/o M/s Royal Enterprises located at Unit No.G-72, GF, CN2-Aggarwal Cyber Plaza-II, NSP District Centre, Wazirpur, Delhi-110034.

Sir,

This is reference to online application no. 2026033103974 dated 04.04.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Rajan on dated 15.04.2026 to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Fire check door not provided in kitchen.
2. Exit door width is less than 1.5m & alternate exit width of 1.5 m not provided.
3. Manually operated electric fire alarm is not provided.
4. The required exit signages are not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 you may advise the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


27/04/26
(S. K. Dua)

Chief Fire Officer
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026033103974 dated 04.04.2026.