

C-51

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6/DFS/MS/2026/WZ/School/50

Dated 15/04/2026

FIRE SAFETY CERTIFICATE

Certified that the Royal International School located at Nangloi to Najafgarh Road, Kotla Vihar, Phase-II, New Delhi- 110043 comprised of Two Blocks- (Ground plus One upper floor in each block) was issued FSC vide this department letter no. F6/DFS/MS/School/WZ/2022/493 dated 09.05.2022. The premises was re inspected by the officer concerned of this department on 01.04.2026 in the presence of Ms. Shalini Chhibber and observed that management has added two more floors on block A of the existing building and now the building is comprised of Two Blocks (Block A- Ground plus three upper floors & Block B- Ground plus one upper floor). All the fire prevention & fire safety arrangement provided in the building was found as per Rules and in good working condition. The premises have therefore complied with the requirements under rule 33 of Delhi Fire Service Rules, 2010 and the building/ premises is fit for occupancy class "Educational Building" (Group B) with effect from15.04.2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on15.04.2026 at New Delhi by


S.K. Dua
Dy. Chief Fire Officer (WZ)
Delhi Fire Service



Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, Royal International School located at Nangloi to Najafgarh Road, Kotla Vihar, Phase-II, New Delhi- 110043.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Royal International School located at Nangloi to Najafgarh Road, KotlaVihar, Phase-II, New Delhi- 110043.
2. Type of Occupancy : Educational
3. Building Comprised of : 02 Blocks (Block A- Ground plus Three upper floors & Block B- Ground Plus first floor).
4. Type of Case : Addition/ Alteration
5. Details of Previous NOC : F6/DFS/MS/School/WZ/2022/493 Dated- 09/05/2022
(For 02 Blocks- Ground plus First floor)
6. Fire Safety directives letter No : NBC Part-IV/ DOE Circular 3298-3398 Dated 01/03/2011
7. Date of inspection : 01/04/2026
8. Name of Inspecting Officer : R.K.Sinha, ADO (Jawala Puri)
9. Name and designation of officers
From the building side : Ms. Shalini Chhibber
10. Year of Construction : 2006 (02 Blocks - G+1) & 2009 (Block A- 2nd and 3rd floor)
11. Applicant's letter No. : E Mail ID dated 09/03/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV / DOE Circular Dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	4.5 m & 3.8 m	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		Block A- 02 Block B- 02 & 1 Ramp	MR
	• Upper Floors	Block A- 02 Block B- 02	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases		Block A- 1.5 m x 2 Block B- 1.34 m x 2 & Ramp 2 m	MR
	• Upper Floor	1.5 m each in A- Block, 1.5 m/ additional staircase of 75 cm if less than 1.5 m in B- Block	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits		NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02 in A Block	Provided	MR
	e. Width of Corridor	1.5 m in each block	Provided	MR
	f. Door Size	1 m in both blocks up to first floor and 1.2 m for A Block 2 nd and 3 rd floor	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	16 Nos.	Provided	MR
	• Types	ABC/ Co2 Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7.	Automatic fire detection and alarming system			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			NA
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			NA
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			NA
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			MR
	➤ Discharge of pump	450 lpm in Block A	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			NA
16.	Provision of Lifts.			NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply			NA

Refuge Area.			
➤ Total Area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire Control Room			
• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter of even no. 849 dated 27/11/2025.

Keeping in view of substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/Jawala Puri.

~~Delivered~~ 11/6/24

~~ADCF/WZ~~

~~Pr. Director~~

~~My. ADO (WZ)~~

~~ADO (JSP)~~

~~ADCF/WZ~~

F.P. wing

~~ADCF~~ 07/04/26

By. ADO to JSP.

~~08/04/26~~

F.T. please.

~~ADCF~~ 09/04/26

849, F-T letter is put up for signi. please

~~ADCF~~ 10/04/26

~~ADCF~~ 10/04/26