

C/129

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 304

Dated: 23/06/2025

To

The Joint Commissioner of Police,
Licensing Unit, First Floor,
Police Station Defence Colony,
New Delhi-110049

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Royal Plaza Guest House situated at 8167, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

Please refer to online portal (etl.mcdonline.nic.in) application No. **2025061009901** dated 10/06/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on 17/06/2025 in the presence of Mr. Afsar Alam (Manager) of the Guest House. During course of inspection, the shortcomings observed are as below.

1. First-Aid Hose Reel provided found non-functional.
2. Terrace level fire pump provided but not on auto mode.
3. Overhead water tank exclusive for firefighting found tapped for domestic uses.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)

DIRECTOR

Ph. 011-23414000

Copy to: -

1. Smt. Navraj Kaur, M/s Royal Plaza Guest House situated at 8167, Arakashan Road, Pahar Ganj, New Delhi-110055