

C-45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2025/ 287

Dated: 26/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **R. R Gita Bal Bharti Public School** located at **Jalebi Chowk, Sultan Puri, Delhi-110086**, comprised of **Ground + 02 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/School/WZ/2022/121** dated **03.02.2022**. The premises was re-inspected by the officer concerned of this department on **10.03.2025** in the presence of **Sh. Virender (Care Taker)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from 26/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/03/2025 at New Delhi by


(Atul Garg)
DIRECTOR
Ph, 011-23414000
on
my

Copy to :-

1. The Principal, R. R Gita Bal Bharti Public School located at Jalebi Chowk, Sultan Puri, Delhi-110086.

2. The Director of Education, Old Secretariat, Delhi

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : R. R. Gita Bal Bharti Public School, Jalebi Chowk, Sultan Puri, Delhi-86
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 02 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2022/121 dated 03.02.2022
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 10.03.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Virender (Care Taker)
9. Year of Construction : 1994
10. Applicant's letter No. : OD No.11877 dated 28.01.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible Accessible NA	Accessible 4.5m NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	03nos. -NA-	03nos. -NA-	MR -NA-
	e. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5m -NA-	1.35m x 3 -NA-	MR(Old case) -NA-
	f. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5m	Provided	MR
	f. Door Size	1m	1m x 2	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	-NA- 12 a/c per hour	-NA- Natural ventilated	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12nos. ABC/CO2 ISI marked	Provided ABC/CO2 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01nos. 30mm 5m	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel 	-NA- -NA-	-NA- -NA-	-NA- -NA-

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450lpm	450lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000ltr	10,000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room			

	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/WZ/2022/121 dated 03.02.2022 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010

Ajay Kumar Sharma
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

Ajay Kumar Sharma
17/03/2025

Ajay Kumar Sharma
17/03/2025

Ajay Kumar Sharma
18/3

Ajay Kumar Sharma
18/3

Ajay Kumar Sharma
19/3/2025

Ajay Kumar Sharma
19/3/2025

Ajay Kumar Sharma
20/03/25

Ajay Kumar Sharma
20/03/25

FT letter is put up for kind perusal and signature please.

Ajay Kumar Sharma
Director

Ajay Kumar Sharma
25/03/25

FOI-1017-2022
dated 18/3/2025