



No. F6/DFS/MS/School/NDZ/2025/ 457

To,

The Manager,
R. S. Public School
584/1, Vill., Mandoli,
Nand Nagri, Delhi - 110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o R. S. Public School located at 584/1, Vill., Mandoli, Nand Nagri, Delhi - 110093.

Sir,

This has a reference to your Outdoor diary No. 447 dated 09/04/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 14/05/2025 in the presence of Mr. Jai Singh (Manager) and observed that building comprised of ground plus one upper floor.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 220 LPM found removed.
3. Overhead water storage tank of capacity 2500 liters found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B – Block, Yamuna Vihar, Delhi - 110094.