



No. F6/DFS/MS/School/NDZ/2025/ 950

Dated: 06/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **R.S. Public School** located at **584/1, Vill. Mandoli, Nand Nagri, Delhi-110093**, building comprised of Ground plus one upper floor only, owned/occupied by **R.S. Public School** was issued FSC vide letter No. F6/MS/DFS/2006/2637 dated 19/09/2006. The school building was re-inspected by the officer concerned of this department on 18/07/2025 in presence of Mr. Jai Singh (Manager) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **"Educational Building" (Group "B")** with effect from 06/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 06/08/2025 at New Delhi by.

  
5/8/2025  
**VIRENDRA SINGH**  
**CHIEF FIRE OFFICER**  
**DELHI FIRE SERVICE**

**Copy to: -**

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Principal, R.S. Public School, 584/1, Vill. Mandoli, Nand Nagri, Delhi-110093.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.



# N/06

## INSPECTION REPORT

1	Name & address of the building	R.S. Public School located at 584/1, Vill. Mandoli, Nand Nagri, Delhi-110093.		
2	Building is comprised of	Ground plus one upper floor		
3	Type of occupancy	Educational Building Group- B		
4	Type of case	Renewal		
5	Details of previous FSC	F6/MS/DFS/2006/2637 dated 19/09/2006		
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	18/07/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Jai Singh (Manager)		
10	Year of construction	2001		
11	Applicant's letter no.	Outdoor Dairy No. 3334 dated 02/07/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	Requirement NBC/UBBL	Provided at site	Remarks MR/NMR
1.	<b>Access to Building:</b>			
	A Road width	6.0 mtrs.	06 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width, Type and Arrangement of Exits:</b>			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR
	Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtr.	1.50 mtr. & 0.98 mtr.	MR
	Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	01 no.	MR
	E Width of corridor	1.20 mtrs	1.20 mtrs	MR Old case
	F Door size	1.0 mtr.	1.0 mtr.	MR
3.	<b>Compartmentation:</b>			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4.	<b>Smoke Management System:</b>			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A



N/07

<b>5. Fire Extinguisher:</b>				
A	Total numbers	06 nos.	06 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	Required	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no.	01 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	Provided	N/A
10	Automatic Sprinkler System:	N/A	N/A	N/A
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump each block	220 LPM	220 LPM	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

②



R.S. Public School located at 584/1, Vill. Mandoli, Nand Nagri, Delhi-110093

<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
	<b>A</b>	Underground tank capacity	N/A	N/A
	<b>B</b>	Draw-off connection	N/A	N/A
	<b>C</b>	Fire service inlet	N/A	N/A
	<b>D</b>	Access to tank	N/A	N/A
	<b>E</b>	Overhead tank capacity	2500 liters	2500 liters
<b>15</b>	<b>Exit Signage:</b>		N/A	N/A
<b>16</b>	<b>Provision of Lifts:</b>			
	<b>A</b>	Pressurization of lift shaft	N/A	N/A
	<b>B</b>	Pressurization of lift lobby	N/A	N/A
	<b>C</b>	Communication in lift car	N/A	N/A
	<b>D</b>	Firemen's grounding switch	N/A	N/A
	<b>E</b>	Lift signage	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>		N/A	N/A
<b>18</b>	<b>Refuge Area:</b>			
	<b>A</b>	Total area	N/A	N/A
	<b>B</b>	Location	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
	<b>A</b>	Detector system panel	N/A	N/A
	<b>B</b>	Flow switch panel	N/A	N/A
	<b>C</b>	PA system panel	N/A	N/A
	<b>D</b>	Battery backup	N/A	N/A
	<b>E</b>	Building floor plans	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued by this department vide letter no. F6/DFS/MS/School/NDZ/2025/457 dated 26/05/2025 has been rectified.


Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of FSC issued vide letter no. F6/MS/DFS/2006/2637 dated 19/09/2006, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

  
21/7/2025

Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: ADO /Laxmi Nagar

~~DO/Estt~~

Submitted for approval to.


  
22/7/2025

~~Dy C.O. (N/2)~~

C.F.O.

  
22/7/2025

Principal Director

  
23/07/25

CFO to Secy.

  
23/07/25

ADD (N/2)

