

C/114

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2024/SZ/ 10

Dated: 03/01/2025

To,

The Owner/occupier,  
Rudra International School, Plot No. 9,  
Sainik Enclave, Mohan Garden, New Delhi-110059.

**Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o Rudra International School at Plot No. 9, Sainik Enclave, Mohan Garden, New Delhi-110059.**

Sir,

Please refer to your letter dated 19.12.2024 received through online email Id [delhischools3@gmail.com](mailto:delhischools3@gmail.com), on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 20.12.2024 in the presence of Sh. Bharat Gupta (Manager), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school running at ground and first floor only in a building comprised of ground plus three upper floors (2<sup>nd</sup> & 3<sup>rd</sup> floor used for owner residence, and following shortcomings were observed: -

1. Two staircases having width of 1.50 & 0.90 m found provided against requirement of two staircases with width of 1.50 m each upto terrace level.

In view of above, fire safety certificate cannot be issued at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.