



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 153

Dated: 04/04/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Ruhaan Guest House situated at Prop. No. 8641/59, Arakashan Road, Pahar Ganj, New Delhi-110055

Sir,

This has reference to online (etl.mcdonline.nic.in) application Id. 2025032004115 dated 20/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 29/03/2025 in the presence of Sh. Sanjay Magan of the guest house. During course of inspection, the shortcomings observed are as below.

1. Terrace level fire pump was not on auto mode.
2. Overhead water storage exclusive for firefighting found used for domestic purpose.
3. Lift signage found removed.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Authorized Signatory M/s Ruhaan Guest House situated at Prop. No. 8641/59, Arakashan Road, Pahar Ganj, New Delhi-110055