

G/33

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2025/ 133

Dated: 04/03 /2025

To

Mr. S. K. Saxena (Authorized Signatory),  
Rukmani Devi Jaipuria Public School,  
23, Rajpur Road, Delhi - 110054.

**Sub:-** Regarding renewal of Fire Safety Certificate (FSC) in r/o (1) **Rukmani Devi Jaipuria Public School, (2) Seth Beni Pershad Jaipuria Prep. School** located at **23, Rajpur Road, Delhi - 110054.**

Sir,

This has reference to letter outdoor diary No. 11983 dated 30.01.2025 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned of this department on 20.02.2025 in the presence of Manager and it was observed that building is comprised of Basement + ground + 03 upper floors. During the inspection, following shortcomings were observed:-

1. Fire extinguishers provided but not functional.
2. Automatic sprinkler system provided in basement but not functional.
3. Fire pump not in auto start mode.
4. Exit signages are not adequately provided.
5. Domestic LPG cylinders used in science lab.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

Tel: 011-23414000

27/2 27/02

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.